



**B R I T I S H
W O O D W O R K I N G
F E D E R A T I O N**

U-value Calculation Certificate

This is to certify that

PERFORMANCE DOORSET SOLUTIONS LTD

of

**Greenvale Business Park, Todmorden Road, Littleborough
Lancashire OL15 9AZ**

has achieved a thermal transmittance U-value of:

1.3 W/m²K

for: **BR 443 Model Stormproof Casement Softwood Window**

In accordance with calculations carried out on the BBA software tool, in compliance with BS EN ISO 10077-1:2006 using the following criteria:

Timber density:	510 kg/m ³
Frame thickness, d₁:	69 mm
Casement thickness, d₂:	57 mm
Thermal transmittance of glazing:	1.0 W/m ² K
Double glazing cavity size:	14 mm
Gas filling:	Argon
Low Emissivity coat:	0.03 x 1
Type & linear thermal transmittance of spacer:	Warm edge 0.027 W/mK

Certificate Number: **061756-4**

Notified Body Name and Number: **British Board of Agrément NB 0836**

Date of issue: **May 2015**

The window dimensions are based on the test specimen size in accordance with BS EN 14351-1:2006+A1:2010 Table E.1. This U-value is not suitable to be used in window energy ratings calculations or U-value simulations according to BS EN ISO 10077-2. This certificate remains the property of BWF and shall be returned upon request.

The Building Centre, 26 Store Street, London WC1E 7BT
Tel: 0844 209 2610 • Fax 0844 209 2611
e-mail: bwf@bwf.org.uk • web: www.bwf.org.uk